

Räume	Messung durch Uni Mai 09 Werte PCB je ng/m³	Messung Informatik Juli 09 Werte PCB je ng/m³	Messung BLB Juli 09 Werte PCB ng/m³	Messung Informatik August 09 Werte PCB ng/m³	Messung BLB August 09 Werte PCB ng/m³
Socket 04					730
Socket 07					388
Socket N11			186,5		
Socket N12			429		
Erdg. 4			210		
Erdg. 06					870
Erdg. 10			127,5		
101	2264	1500	305	470	
102		2600			
103					705
110	2393				
131			655		
205		3500	710	1400	1085
207					2055
208	1057				
211	1554				
217					2165
218a			115	980	
219	426	1300			
222	620	1000			
224		980			
227	1766	2600			
228			433,5		
304 MA		4800		940	1345
304 Bib	2514		256	1400	1040
307		530	381,5		
308	1317				
309		1500			
314		3200			
316		2300	398,5	920	400
317		1700			
Flur 319		2000			
321					411,5
325	1251	2000			
328/329			333,5		471
330			468		
332		2300			
701			348		1090
703			304,5		
707					1195
717			482,5		905
720			342		
801					665
806					325
820					1490
832			530		965
900			1215		1760
905			505		1480
906		760	730		
908		2000			
909			446		
911		4600	402,5		
915			1105		1295
1001			520		
1002(1000)			765		755
1003			1215		825
1006			439		
1007			277		
1009					1510
1101a					
1102					890
1105					1395
1102/1108			1020		
1115		4300			
1108/1116			319,5		
1109/1117		3400	256	540	
HS A		2000	1590	1900	
HS B			2120		
HS C			1200		
HS D			1790		
Audimax			unten1215/oben1450		
Flur 1. OG					1625
Flur EG-Ost					1605
Flur EG-West					925